XA 03 E/FM42iEX1/05.25

Valid starting from Hardware V 2.1 Software V 1.29




# Flowmax® 42i

# Ultrasonic flow metering / dosing device

Ex-documentation for the Operating manual

According to IECEx and directive 2014/34/EU Ex-zone 1









# Contents


Flowmax® 42i

Cor	ntents	3
	Variant code	
	Labelling	
	Name plate	
	Special conditions	
5.	Warnings	7
6.	Additional information	7
7.	Electrical wiring	8
8.	Display and user menu of FlowCon 200i	10
9.	Dimensions and weight	10
10.	Technical specifications	13



## 1. Variant code

Flowmax 42i with variant code



is a device within the scope of IECEx and Directive 2014/34/EU. When used as equipment of group II, category 2G for zone 1, explosive gas atmospheres, as well as under consideration of the intended use, this flowmeter does not pose any ignition hazard of its own.


The ignition hazard analysis was carried out in accordance with the IECEx and ATEX-Directive 2014/34/EU. Used standards are: EN IEC 60079-0, IEC 60079-0, EN 60079-18 IEC 60079-18.

# 2. Labeling

The EX-labelling is

IECEx Ex mb IIC T6 Gb

ATEX (Ex) II 2G Ex mb IIC T6 Gb




The special conditions according to chapter 4 of these Operating manual must be followed!



### 3. Name plate

The flowmeter is provided with a name plate and a warning notice.

An example of a name plate is shown below:



- 1 Device type
- 2 Manufacturer
- 3 Notified authority
- 4 Year of manufacture
- 5 Order-Code
- 6 ATEX Labeling
- 7 IECEx Labeling
- 8 Certificate number

The warning notice is shown below:



WARNUNG - NICHT UNTER SPANNUNG TRENNEN

WARNUNG - GEFAHR DURCH ELEKTROSTATISCHE AUFLADUNG - SIEHE BETRIEBSANLEITUNG

WARNING - DO NOT SEPERATE WHEN ENERGIZED

WARNING - POTENTIAL ELECTROSTATIC CHARGING HAZARD - SEE INSTRUCTIONS



## 4. Special conditions

The technical data and the following instructions must be observed.

• Do not disconnect under voltage! Electrically generated sparks can ignite an explosive atmosphere. Disconnect the connecting cable outside explosive atmospheres or switch off the voltage beforehand.



- Measures must be taken to avoid electrostatic charges.
- The medium temperature must not exceed 50°C.
- The ambient / storage temperature must not exceed 50°C.
- The risk of mechanical hazard is classified as low.
- The measuring device must not be exposed to UV radiation.
- The measuring device must be installed such that danger of mechanical damage is avoided.
- The meter must be visually inspected for mechanical damage at regular intervals. In case of damage, the measuring device must be taken out of service immediately.

## 5. Warnings

- Use only for intended use.
- Assembly, electrical installation, commissioning and maintenance of the flowmeter may only be performed by trained and qualified personnel who have been instructed in explosion protection and who have been authorised by the plant operator. The qualified personnel must have read and understood the operating manual of the flowmeter including this supplementary Ex documentation and follow its instructions.



- The installer must ensure that the flowmeter is correctly connected according to the electrical connection diagrams.
- Unused electrical wires must be connected individually to unused potential-free terminal blocks.

#### 6. Additional information

- There are no galvanically isolating components, e.g. optocouplers or relays, in the electronics.
- There are no switching contacts.
- There are no cells or batteries.
- The thermal protective device can be reset.
- The energy content of the ultrasonic signal transmitters/transducers on the surface to the measuring channel and the environment is below the permissible limit values according to standard EN IEC 60079-0 / IEC 60079-0.

NOTICE!

Electrical wiring



# 7. Electrical wiring

#### Cable 8-wire with 1-wire communication

<u>Wire configuration defined by manufacturer.</u>
The inputs and outputs can be reprogrammed for specific applications.

Colour	Function	Description
Red	24 VDC	Power supply: 2027 VDC
Brown	Digital output Q1	Digital output Q1
Black	GND	Ground: 0 V
Green	Digital output Q2	Digital output Q2
Violet	Analog output QA	420mA; 020mA or 010V
		Example: 0I/min => 4mA
		6l/min => 20mA (depending on diameter)
		Empty pipe Alert => 3.5mA
Yellow	Communication	Communication interface
Orange	Digital input I1	Digital input I1
Blue	Shielding	EMC safety

For a detailed description of the functions of the digital inputs and outputs, see the Flowmax 42i operating manual.

#### Cable 8-wire with 2-wire communication

Wire configuration defined by manufacturer.

The inputs and outputs can be reprogrammed for specific applications.

Colour	Function	Description				
Red	24 VDC	Power supply: 2027 VDC				
Brown	Digital output Q1	Digital output Q1				
Black	GND	Ground: 0 V				
Violet	Analog output QA	420mA; 020mA or 010V  Example: 0l/min => 4mA 60l/min => 20mA (depending on diameter)  Empty pipe Alert => 3.5mA				
Orange	Digital input I1	Digital input I1				
Yellow	Communication	RS 485 A				
Green	Communication	RS 485 B				
Blue	Shielding	EMC safety				

For a detailed description of the functions of the digital inputs and outputs, see the Flowmax 42i operating manual.

#### Important!

The flowmeter Flowmax 42i may only be operated within the limits indicated on the nameplate and in the instruction manual/data sheet. Unauthorised operating conditions can lead to overload, damage or defects.



IMPORTANT!




# 8. Display and user menu of FlowCon 200i


Flowmax 42i in the Ex-version has no display. To display current measured values and to set application-specific parameters, the use of the display and configuration unit FlowCon 200i is required, see operating manual FlowCon 200i. This does not have an Ex-approval and may only be used outside a hazardous area.




# 9. Dimensions and weight


#### Process connection as clamp according to DIN 11864-4 BKS Form A










	А	В	С	D	Е	F	G	weight
diameter	process connection							
	DIN 11864-4 BKS Form A	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[g]
DN03	DN10	167.5	98	25	43	18	23	910
DN05	DN10	167.5	98	25	43	18	23	910
DN07	DN10	167.5	98	25	43	18	23	910
DN10	DN10	170.5	95	26.5	43	18	23	910
DN15	DN15	175.5	90	29	48	23	25	1050



# **Process connection as TriClamp according to DIN 32676**










	А	В	С	D	Е	F	G	weight
diameter	process connection Tri Clamp							
	DIN 32676	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[g]
DN03	series B D25 NW8	167,5	98	25	43	18	23	910
DN05	series B D25 NW8	167,5	98	25	43	18	23	910
DN07	series B D25 NW8	167,5	98	25	43	18	23	910
DN10	series B D25 NW8	170,5	95	26,5	43	18	23	910
DN15	series A D34 DN15	175,5	90	29	48	23	25	1050



# Process connection as inch inner thread








	А	В	С	D	E	F	G	weight
diameter	process connection							
	inch inner thread	[mm]	[mm]	[mm]	[mm]	[mm]	[mm]	[g]
DN03	G 1/2	167.5	98	25	43	18	23	890
DN05	G 1/2	167.5	98	25	43	18	23	890
DN07	G 1/2	167.5	98	25	43	18	23	890
DN10	G 3/4	170.5	95	26.5	43	18	23	890
DN15	G 1	175.5	90	29	48	23	25	1030

12 M I B



## 10. Technical specifications

#### Housing

Medium temperature 0...+50°C

Protection class IP 65
Pressure nominal PN 10

Material PP (Polypropylene)I

The risk of mechanical hazards is classified as low.

**Electronics** 

Power supply 20...27VDC

Power consumption at 24VDC 3.6W

Connection Cable 8-wire, a separately certified plug can be connected to the cable

Ambient temperature 0...+50°C

Storage/

Transport temperature 0...+50°C

Current output QA 0/4...20 mA or 0...10V, active

Start and end value adjustable, Ground connected to supply ground

Error signal according to NAMUR NE43 at 4...20mA

In case of short circuit, no additional heating compared to normal

operation can be detected.

Digital output Q1/2 Transistor circuit NPN and PNP logic, max. 100mA

Output voltage according to DIN 19240:

≤5V corresponds to LOW ≥12V corresponds to HIGH

Short-circuit proof, in case of short-circuit the output is switched off.

Frequency 0...10kHz

Data interface Communication interface

Sealing compound Polyurethane potting / encapsulating resin

The Flowmax 42i measurement system meets the general EMC immunity requirements according to CE, EN 61000-6-3, EN 61000-4-2, EN 61000-4-3, EN 61000-4-4, EN 61000-4-5, EN 61000-4-6. It is in conformity with the requirements of the EC Directives and bears the CE label.

#### **Material specifications**

Non-metallic	Housing material	Sealing	Name plate / warning		
housing component	electronics	compound	notice		
Material	Polypropylene	Polyurethane	Metallised polyester film		
Colour	Natural	PU: beige	Silver		
		Hardener: brown			
Temperature index TI (RTI) (IEC 216)	110°C				
Temperature range of the application	0100°C	-40125°C	-40150°C		
Moisture absorption (ISO 62)		0.4%			
Flammability (UL94)	HB	V0			



MIB GmbH Messtechnik und Industrieberatung Bahnhofstr. 35 D-79206 Breisach Tel. 0049 / (0)7667 / 20 777 90 Fax 0049 / (0)7667 / 20 777 99 E-Mail: info@mib-gmbh.com Internet: www.flowmax.de

